

CHP DATA SHEET

Unit No: 200278 200279

Site Address:

Name	Astra Zeneca UK Ltd
Address	Avlon Works, Severn Road Hallen
Town/City	Bristol
County	
Post Code	BS10 7ZE
Contact Names	Martin Webster - Utilities & Energy Manager Martin Edwards - Project Manager
Telephone Number	(MW) 0117 938 5421 / (ME) 0117 938 5626
Fax Number	0117 938 5656
Mobile Number	(MW) 07787 154240 / (ME) 07825 530013
Email address	martin.webster@astrazenica.com martin.edwards@

Rating: CGC-1400CS-080-NG-50 *Type of Control*
RMQ

Engine Type: Cummins QSK 60G V 16

Engine Serial No: No.1 (200278) = 33176065, No.2 (200279) = 33170616

Alternator Type: Cummins 1400 GQVC

Alternator Serial No: No.1 = K08KAVAZ000, No.2 = L08KAWK470

CHP Link Telephone: No.1 = 01179 824544, No.2 = 07584 217952

Running Hours: 24 / 7
(e.g. 17 / 24 hrs per day)

Hours Service: ?
(interval e.g. 1000hrs..)

Service Contract: Eco2synery (Optima) - Fully inclusive ▼

Availability:

Commissioning Date: 05/03/2010 *Commissioning Engineer*
Mick Webb / James Hudson

Site Contact: via Dalkia Service Desk - (SMC) 02476 474671

Heat Dump Details Combined HT & LT (Jacket Water & Intercooler) ▼
(JW primary, LPHW sec, Intercooler, dual coil etc..)

Import / Export Fitted?: Not Required / Fitted ▼

Standby Feature: Not Required, Parallel Operation Only ▼

Project No: Z256 *Project Manager*
Alex Smith

